

FR_720278

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE Product Power Distribution Unit Li-ion Power Distribution Unit Name and address of the applicant Jiangsu Skyworth New Energy Technology Co.,Ltd 3F South, Plant 4, No.599 Taishan Road, High-tech Zone, Suzhou City, Jiangsu Province - China Name and address of the manufacturer Jiangsu Skyworth New Energy Technology Co.,Ltd 3F South, Plant 4, No.599 Taishan Road, High-tech Zone, Suzhou City, Jiangsu Province - China Name and address of the factory Jiangsu Skyworth New Energy Technology Co.,Ltd 3F South, Plant 4, No.599 Taishan Road, High-tech Zone, Suzhou City, Jiangsu Province - China Note: When more than one factory, please report on page 2 ☐ Additional Information on page 2 Ratings and principal characteristics See Annex Trademark / Brand (if any) Solavita Customer's Testing Facility (CTF) Stage used Model / Type Ref. See Annex Additional information (if necessary may also be reported on page 2) ☐ Additional Information on page 2 A sample of the product was tested and found to IEC 62619:2022 be in conformity with As shown in the Test Report Ref. No. which CPXU-ESH-P24081948 forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE 33 avenue du Général Leclerc

92260 Fontenay-aux-Roses, FRANCE CENTRAL DES

www.lcie.fr

Date: 17/10/2024

INDUSTRIES ELECTRIQUES S.A.S au capital de 15.745.984 € RCS Nanterre B 408 363 174

33 avenue du Sépéral les Est Julien GAUTHIER F - 92266 FONTENAY AUX ROSES

Certification Officer



FR_720278

ANNEX

Model	Nominal voltage (V d.c.)	Rated capacity (Ah)	Rated Power (kWh)
SWR2.56-H1	51.2	50	2.56
SWR5.12-H1	102.4	50	5.12
SWR7.68-H1	153.6	50	7.68
SWR10.24-H1	204.8	50	10.24
SWR12.80-H1	256	50	12.80
SWR15.36-H1	307.2	50	15.36
SWR17.92-H1	358.4	50	17.92
SWR20.48-H1	409.6	50	20.48



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE 33 avenue du Général Leclerc 92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 17/10/2024

LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre Belos 3/3 174 re: Julier GAUTHIER
33 avenue du Geloral Recepte: Julier GAUTHIER
F - 92266 FONTENAY AUX ROSEErtification Officer